



City of Plymouth

STANDARD SPECIFICATIONS FOR WATERMAIN CONSTRUCTION

CITY OF PLYMOUTH, MINNESOTA

January 2024

ENGINEERING DIVISION

3400 PLYMOUTH BLVD
PLYMOUTH, MN USA 55447-1482
TELEPHONE (763) 509-5500

A handwritten signature in black ink, appearing to read 'Michael Thompson', is positioned above the printed name.

Michael Thompson, P.E.
Public Works Director

These specifications are intended for inclusion into the contract documents.
They only address the technical specifications and construction details of the referenced section.

THIS PAGE LEFT BLANK FOR PRINTING

SECTION 02200
STANDARD DETAIL SPECIFICATIONS
FOR
WATERMAIN CONSTRUCTION

CITY OF PLYMOUTH, MINNESOTA USA

January 2024
INDEX

02201 [SCOPE OF WORK](#)

02202 [USE OF EXISTING WATER SYSTEM](#)

02203 [SPECIFICATIONS WHICH APPLY](#)

02204 [WATERMAIN MATERIALS](#)

1. [Pipe Bedding](#)
2. [Polyvinyl Chloride Pressure Pipe \(PVC\)](#)
3. [HDPE Pipe](#)
4. [Pipe Restraints](#)
5. [Tracer Wire for Watermain Pipe](#)
6. [Ductile Iron Pipe \(DIP\)](#)
7. [Gate Valves, Boxes, Valve Box Bases](#)
8. [DIP Fittings](#)
9. [Bolts, Nuts & Roding](#)
10. [Hydrants](#)
11. [Tapping Sleeves and Valves](#)
12. [Building Services and Service Saddles](#)
13. [Insulation](#)
14. [Polyethylene Encasement Material](#)
15. [Sprinkler Systems](#)
16. [Chanel Post & Markers](#)

02205 [WATERMAIN INSTALLATION](#)

1. [Working Hours](#)
2. [Inspection and Handling](#)
3. [Installations of Pipe and Fittings](#)
4. [Pipe Laying Operations](#)
5. [Gate Valves, Boxes, Valve Box Bases and Valve Box Clips](#)
6. [Jacking/Boring](#)
7. [Horizontal Directional Boring](#)
8. [Polyethylene Encasement of Pipeline](#)
9. [Reaction Backing](#)
10. [Joining of HDPE OR PVC Pipe](#)

11. [Remove and Replace Watermain Bolts](#)
12. [Adjust Gate Valve Box](#)
13. [Watermain Stubs Pressure Relieve Provision](#)

02206 [WATERMAIN TESTING](#)

1. [Pressure Testing of Watermain](#)
2. [Conductivity Testing of Watermain](#)
3. [Disinfection of Watermain](#)
4. [Bacteria Testing of Watermain](#)

02207 [MEASUREMENT AND PAYMENT](#)

02208 [WATERMAIN DETAILS](#)

- W-1 [Sewer and water service connection](#)
- W-2 [Hydrant and gate valve installation](#)
- W-3 [Typical Megalug Location](#)
- W-4 [Gate valve and box installation](#)
- W-5 [Watermain wet tap](#)
- W-6 [Watermain bedding](#)
- W-7 [Watermain stub blow off detail](#)
- W-8 [Vertical Offset Detail](#)

02201 SCOPE OF WORK

The work to be done under this contract shall include the furnishing of all labor, materials, tools and equipment to construct complete in place the watermain and all appurtenances as shown on the drawings, plans and as specified herein.

The contractor shall excavate all materials encountered, furnish and compact foundations where required, furnish and install all timbering, sheeting and bracing necessary to safely support the work, remove any ground water encountered during excavation operations, protect, repair, relocate, maintain and restore all sub-surface, surface and overhead structures directly disturbed, damaged or affected by construction operations and furnish all backfill and other appurtenant items and services as necessary.

All site grading must be completed, certified by the project engineer and all off-road grading equipment removed from the site before starting any public utility work. When installing public utilities in a new residential development all builder and developer construction activity shall pause until the public utilities have been installed, tested and the streets built.

02202 USE OF EXISTING WATER SYSTEM

Only designated city personnel shall have the authority to operate any hydrants or valves that make up Plymouth's water distribution system. **Contractors shall not operate existing gate valves or hydrants.**

It is the contractor's responsibility to make arrangements for receiving water from public or private sources, secure necessary permits and pay regular charges. City water may be purchased at the public works facility, [14900 23rd Ave.](#) or at the Zachary Lane Treatment Plant, [4295 Zachary Lane](#). Under no circumstances shall existing hydrants be used to supply water.

City personnel shall do the initial filling of new water mains for service installations and testing.

Disposal of any wastewater or any test water into the city sanitary sewer system is not permitted.

A minimum of 48-hour notice is required to the city's utility division if the existing water system requires a shutdown and disruption of service to the existing system customers. In some cases, the shutdown may be required to be completed overnight or on weekends depending on the needs of the system customer.

02203 SPECIFICATIONS WHICH APPLY

All specifications contained herein, including attached detail drawings, together with the construction plans for the designated project or projects and including current versions of those portions of the following specification, as indicated by paragraph or designation number, shall apply: American Society for Testing Materials ([ASTM](#)); American National Standards Institute ([ANSI](#)); American Water Works Association ([AWWA](#)); Minnesota Department of Transportation's Standard Specifications for Construction current addition including Special Provisions ([MnDOT](#)); and the City Engineers Association of Minnesota's Standard Specifications for Utility Construction ([CEAM](#)).

02204 WATERMAIN MATERIALS

All watermain pipes, hydrants, valves, fittings and all appurtenances shall be new materials, free of any defects and shall be of the type, size, strength, and quality as shown on the plans and as specified herein and/or as indicated in the special provisions.

The contractor may be required to secure and deliver to the city engineer or designee a written statement from the manufacturer assuring the quality and compliance to the applicable specification of all materials furnished and installed under this improvement project. This shall in no way relieve the contractor of any responsibility as to the quality of materials furnished and installed.

02204.1 PIPE BEDDING MATERIAL –Watermain Materials

Pipe bedding material shall be in accordance with Standard Detail Plate [W-6](#), utilizing sand conforming to MnDOT specification [3149.2B](#) or 3/4-inch to 1.5 inch clear rock as determined by the existing soils conditions. The contractor shall provide certification of the materials being used and will be required to perform field sampling for gradation test of any bedding materials used as required by the city engineer. Copies of test results shall be submitted to the city in a timely manner. Bedding shall be considered incidental to the pipe installation unless noted otherwise in the contract documents.

02204.2 POLYVINYL CHLORIDE PRESSURE PIPE (PVC) –Watermain Materials

PVC Water Main Pipe shall conform to the latest revision of AWWA's Specification C900 for 4 inches-24 inches dia. PVC pipe. All 4-inch to 24-inch pipe shall be a minimum Pressure Class of 235 psi, DR 18. C909 pipe. Four inches-12 inches dia. PVCO pipe will be considered in place of C900 with written approval of the city engineer.

All pipes shall be marked with the manufacturer's name, date, nominal size, type of plastic and pressure rating. **All PVC pipe used for potable water lines shall be blue in color.** Pipe shall be new and manufactured within the past 12 months, as determined from the date stamp on the pipe, and free of defects. Pipe will be rejected if surface chalking from UV exposure is visible. Pipe O.D. shall be equivalent to ductile iron pipe of the same nominal size. Maximum length of each PVC section of pipe between elastomeric rings shall be 20 feet (± 1 inch) for all sizes. Fusible PVC pipe shall be extruded with plain ends and be a standard 40 feet in length.

2A. PVC PIPE JOINTS

Pipe joints shall consist of an integral wall section with a factory installed, solid cross section elastomeric ring which meets the requirements of ASTM F-477. The bell section shall be designed to be at least as hydrostatically strong as the pipe wall and meet the appropriate requirements of AWWA for C900, and C909 pipe.

2B. Fusible PVC Pipe Joints

Pipe joints shall be plain, non-bell ends, butt-fused together conforming to the requirements of AWWA C900. Butt fusion fittings shall have a manufacturing standard of ASTM D2241. Molded and fabricated fittings shall have a pressure rating equal to the pipe unless otherwise specified in the plans. Fabricated fittings are to be manufactured using data loggers. Temperature, fusion pressure, and a graphic representation of the fusion cycle shall be part of the quality control records.

02204.3 HDPE WATERMAIN PIPE –Watermain Materials

HDPE pipe for horizontal directional drilling shall be HDPE AWWA C906 DIPS and a Dimension Ratio (DR) as shown on the drawings. Pipe shall be new, manufactured within the past 12 months as determined from the date stamp on the pipe and free of defects. Pipe will be rejected if surface chalking from UV exposure is visible. The pipe shall contain no recycled compound except that generated in the manufacturer's own plant. The pipe shall be homogeneous throughout and free of visible cracks, holes, gouges, voids, foreign inclusions, or other defects that may affect the wall integrity. The materials shall be listed by the Plastic Pipe Institute (PPI), a division of the Society of the Plastic Industry in PPI TR-4 with a 73° F hydrostatic design basis of 1,600 psi and a 140° F hydrostatic design basis of 600 psi. The PPI listing shall be in the name of the pipe manufacturer and shall be based in ASTM D 2837 testing.

3A. BUTT FUSION FITTINGS FOR HDPE PIPE

HDPE fittings shall be PE4710 HDPE, Cell Classification of 345464C as determined by ASTM D3350-99 and approved for [AWWA](#) use. Butt fusion fittings shall have a manufacturing standard of ASTM D3261. Molded and fabricated fittings shall have a pressure rating equal to the pipe unless otherwise specified in the plans. Fabricated fittings are to be manufactured using data loggers. Temperature, fusion pressure, and a graphic representation of the fusion cycle shall be part of the quality control records. All fittings shall be suitable for use as pressure conduits, and per AWWA C906, have nominal burst values of three-and-one-half (3-1/2) times the Working Pressure Ratings (WPR) of the fittings.

3B. FLANGED AND MECHANICAL JOINT ADAPTORS

Flanged and Mechanical Joint Adaptors shall be PE4710 HDPE, Cell Classification of 345464C as determined by ASTM D3350-99, Flanged and Mechanical Joint Adaptors shall have a manufacturing standard of ASTM D3261. Fittings shall have a pressure rating equal to or greater than the pipe unless otherwise specified on the plans. Backed rings for flanged and mechanical joint adaptors shall be ductile iron, and bolts for fasteners shall be stainless steel, ASTM F 593 Type 304.

02204.4 PIPE RESTRAINTS –Watermain Materials

All watermain fittings shall be restrained to the pipe using Megalugs manufactured by [EBAA Iron, Inc.](#), Series 2000PV restraints for PVC and HDPE pipe and Series 1100 restraints for DI or CI pipe, or [Sigma ONE-LOK](#) restraints, or STAR Series 4000 for PVC and HDPE pipe and Series 3000 for DI or CI pipe, or SIP Industries EZ Grip for PVC and HDPE or approved equal. All vertically installed bends shall be restrained with stainless steel rodding. Pipe restraints shall be shown on plans and calculations provided to the city engineer for approval.

02204.5 TRACER WIRE FOR WATERMAIN PIPE –Watermain Materials

Tracer wire shall be laid with all watermain and water services regardless of pipe material type and shall be 30 mil. insulated, blue-colored coating, #12 minimum, copper, copper clad steel or braided stainless steel, rated for underground service and American made. Open trenching shall use minimum 450lbs. break load. Copperhead Industries 7 by 7 Stranded Copper Clad Steel break load 4700lbs. minimum or approved equal tracer wire shall be used for directional boring, pipe bursting or slip lining watermain. Two parallel wires shall be pulled on each run for redundancy. The tracer wire loops shall be run up all curb boxes and fire hydrants and connected at a rear flange bolt using an aluminum angle iron hydrant tracer wire bracket part # HTWB-7000 made by Vait Products or approved equal. All spliced or repaired wire connections in the tracer wire system

shall be made using a wire connector for two (2) to four (4) #12 wires and made waterproof using an approved buried service wire closure. The buried service wire closure shall be a Dryconn direct bury lug wire connector or approved equal. See Standard Detail Plates [W-2](#) and [W-5](#). Tracer wire lengths greater than 500 linear feet without service laterals or hydrants are to include an approved grade level/in-ground access box, located at the edge of the road right-of-way and outside of the roadway. Tracer wire shall be grounded at all terminal ends (stubs, plugs).

02204.6 DUCTILE IRON PIPE (DIP) –Watermain Materials

Watermain larger than 24-inch shall be ductile iron pipe, thickness class 51, tar coated, Polyethylene wrapped in conformance with ANSI/AWWA C105 A21.5, cement lined in conformance with ANSI/AWWA C104 A21.4; designed to operate at 150 psi plus water hammer.

6A. PIPE JOINTS

Pipe joints shall be Fastite (American Cast Iron Pipe Company), Bell-Tite (James B. Clow and Sons, Inc.) or Tyton (U.S. Pipe and Foundry Company), except that mechanical joint, ductile iron, short body fittings, cement lined, Class 250, shall be used for stub ends and all fittings. Copper straps or approved copper tipped gaskets are required.

02204.7 GATE VALVES, BOXES & BOX BASES –Watermain Materials

7A. GATE VALVES

American Flow Control 2500 series resilient seat wedge type gate valves shall be used on all sizes of watermain. See Standard Detail Plates [W-2](#), [W-4](#) and [W-5](#). No butterfly valves shall be used. Epoxy coating shall be applied to all gate valves, meeting the requirements of AWWA C550. All gate valves shall be assembled with ASTM F 593 Type 304 stainless steel bolts where the bolts are below ground. All gate valves are to be restrained no matter where they are in the system. Gate valves shall operate smoothly without any binding or hesitation if there are operation issues of any type the valve shall be replaced. Valve boxes and base adaptors are incidental to the valve unless these items are called out in the projects bid tab. See Standard Detail Plates [W-2](#) and [W-4](#).

7B. VALVE BOXES

Valve boxes shall be cast iron with #6 bases, screw type round drop cover with “WATER” imprinted on the top (refer to Standard Detail Plate [W-4](#)). The gate valve box shall consist of extended three-piece totaling 7 feet 6 inches in standard height, more sections may be added as required for additional depth. No gate valve rod extensions are allowed unless the valve operating nut is greater than 15 feet deep and approved by the city engineer.

7C. VALVE BOX BASE ADAPTORS

Valve box base shall be [Adaptor Inc.'s Valve Box Adaptor #6 Base](#) or approved equal.

02204.8 DIP FITTINGS –Watermain Materials

DIP Fittings shall be ductile iron casting and have mechanical joints, Class 350 conforming to AWWA specification C153, covering compact fittings. Mechanical joints shall conform to AWWA Specification C111, latest revision, with gaskets made from vulcanized crude rubber compound. Fittings shall be epoxy coated on the inside and outside. [Romac Industries ALPHA Wide Range Restraints](#) may be used in place of traditional restrained couplings, end caps and flanged couplings. Mastic spray is to be used where any uncoated pipe or fitting is exposed such as welds, Megalugs, scraped coating, etc.

02204.9 BOLTS, NUTS & RODDING –Watermain Materials

All underground installed bolts, T-bolts, nuts and any rodding required shall be stainless steel, ASTM F 593 Type 304 for all watermain fittings including mechanical joints, hydrants, valves, tees, bends, taps, etc. Each bolt shall be clearly stamped as a 593 Type 304 stainless steel bolt. No other type of bolts, nuts or rodding will be allowed unless approved in writing by the city engineer. Anti-seize bolt/nut coating or spray/paste compound shall be used on all bolting operations.

02204.10 HYDRANTS –Watermain Materials

Hydrants shall be Waterous # WB67-250 and be bright yellow in color. All below grade nuts and bolts shall be ASTM F 593 Type 304 stainless steel. Hydrants in a phased project must all be the same type. Gate valves with valve box bases and valve boxes shall be required for all hydrants. See Standard Detail Plate [W-2](#).

Hydrants, hydrant valves, and service valves are to be secured to the watermain with MEGALUGS manufactured by EBAA Iron, Inc. or approved equal. Use MEGALUGS at all mechanical joints to tie the hydrant to the gate valve, gate valve to the tee and the tee to the main. Do not use Duc lugs for any type of restraint. See Standard Detail Plates [W-2](#) and [W-3](#).

All hydrant barrels shall be wrapped with Polyethylene encasement.

All hydrants will be installed with a Hydra-Finder 3/8-inch by 5-foot fiberglass rod fully wrapped with highly reflective alternating red and white tape. Metal poles shall not be used. See Standard Detail Plate [W-2](#).

Hydrants shall be painted yellow from the factory. Yellow paint is Waterous Enamel V1814, Bright Yellow or Sherwin Williams CLOW bright yellow. A hydrant's paint shall be touched up at the city's discretion. All hydrants are to be at required height after lawns, boulevards, etc. are finished (sod, mulch, etc.). See Standard Detail Plate [W-2](#). Hydrants shall be "bagged" (covered) with a black poly wrap or approved material immediately after installation and shall remain covered until all testing is complete and they are placed in service. The contractor will then be required to remove and dispose of the covering. Hydrant valves, valve boxes, and base adaptors are incidental to the hydrant unless these items are called out in the projects bid tab.

02204.11 TAPPING SLEEVES AND VALVES –Watermain Materials

Tapping sleeves shall be all stainless steel, with flat-faced flange to mate with standard valves. Tapping sleeves and gate valves are required for all taps 4-inches and greater. Taps less than 4 inches shall be provided with a stainless-steel service saddle. Tapping sleeves shall be a minimum of 6 feet from pipe joints or other fittings. All bolts and nuts used in conjunction with the tapping sleeve installation shall be ASTM F 593 Type 304 stainless steel.

02204.12 BUILDING SERVICES AND SERVICE SADDLES -Watermain Materials

12A. HDPE SMALL DIAMETER SERVICE PIPE

High Density Polyethylene Pipe (HDPE) SDR-9, Copper Tube Size (CTS) pipe shall be used for all small diameter building services conforming to AWWA Specification C901 and ASTM Specification 2737. A minimum of 1-inch outside diameter service shall be installed. A 1.5 inch or larger outside diameter service shall be installed where fire sprinklers are required or design dictates. Service

pipe is to be one continuous piece with no joints or couplings, etc., allowed from main to curb stop. Compression fittings and insert stiffeners are required at all connections. See Standard Detail Plate [W-1](#).

12B. WATER SERVICE PARTS TABLE

The following is a parts list of the components approved for use in a small diameter building water service.

	Part # for Smith-Blair	Part # for Romac	Part # for Ford	Part # for McDonald	Part # for Mueller
1" WATER SVC AWWA C901 SDR 9 CTS					
Stainless Steel Service Saddles	372	306 and 305	FS 313	NA	NA
Corporation Stops (Ball Valve)	NA	NA	FB1000-4-G-NL FB1000-4-Q-NL	74701B-22 74701BQ	P-25008N B-25008N
Curb Stops (Ball Valve)	NA	NA	B44-444M-G-NL B44-444M-Q-NL	76104-22 76104Q	P-25155N B-25155N
Curb Stop Boxes 7-1/2' L Minneapolis Pattern w/rod (1-1/2" base)	NA	NA	EM2-75-46-72R-TW	5614TW	H-10300 / 88703
Curb Box Caps	NA	NA	PS-LID-TW	5614LTW	89375
1-1/2" WATER SVC AWWA C901 SDR 9 CTS					
Stainless Steel Service Saddles	372	306 and 305	FS 313	NA	NA
Corporation Stops (Ball Valve)	NA	NA	FB1000-6-G-NL FB1000-6-Q-NL	74701B-22 74701BQ	P-25008N B-25008N
Curb Stops (Ball Valve)	NA	NA	B44-666M-G-NL B44-666M-Q-NL	76104-22 76104Q	P-25155N B-25155N
Curb Stop Boxes 7-1/2' L Minneapolis Pattern w/rod (2" base)	NA	NA	EM2-75-47-72R-TW	5615TW	H-10300-99002 / 88703
Curb Box Caps	NA	NA	PS-LID-TW	5614LTW	89375

02204.13 INSULATION –Watermain Materials

Insulation board (polystyrene) shall meet the requirements of MnDOT [3760](#). Use a factor of 2 inches of polystyrene equals one (1) foot of ground cover when determining thickness requirements. The 4 feet by 8 feet standard boards shall be orientated to provide a minimum coverage of 1.5 feet beyond the outside edge of the pipe being covered.

02204.14 POLYETHYLENE ENCASEMENT MATERIAL –Watermain Materials

Polyethylene encasement material shall conform to the requirements of AWWA C-105 for tube type installation and 8 mil. nominal film thicknesses.

02204.15 SPRINKLER SYSTEMS –Watermain Materials

All materials shall be equal or better-quality replacement parts for the existing irrigation system being repaired.

02204.16 CHANNEL POST & MARKERS –Watermain Materials

U-Channel post used for structure marking shall be green, 6 feet in length weighting 3lb/foot and punched full length with 3/8-inch diameter holes, 1 inch on center. Marker signs shall be 0.063-inch-thick aluminum blanks measuring 3 inches wide by 8 inches high with a high intensity blue reflectorized background with white 2-inch-high letters. Markers shall be attached to the post with two stainless steel bolts and nuts. Posts and markers shall be considered incidental unless otherwise noted.

02205 WATERMAIN INSTALLATION

02205.1 WORKING HOURS –Watermain Installation

The city engineer or designee shall be notified at least 48 hours prior to commencing any work by calling the engineering division, (763) 509-5500. Contractors are subject to being shut down and or having work rejected if proper notification is not given to the city.

Work shall not commence before 7:00 a.m. nor extend beyond sunset Monday through Friday. On Saturdays, work hours are from 8 a.m. to 6 p.m. No work is permitted on Sundays or holidays unless authorized by the city. Existing roadways shall not be restricted between 7 a.m. to 9 a.m. and 3 p.m. to 6 p.m. unless approved by the city engineer. The definition of “work” also includes the starting of equipment and the delivery of materials to the job site.

02205.2 INSPECTION AND HANDLING –Watermain Installation

Proper and adequate implements, tools, and facilities satisfactory to the city engineer or designee shall be provided and used by the contractor for the safe and convenient prosecution of the work. During the process of unloading, all pipe and accessories shall be inspected by the contractor for damage. The contractor shall notify the city engineer, or a designee of all material found to have cracks, flaws, or other defects. The city engineer or a designee shall inspect the damaged materials and have the right to reject any materials found to be unsatisfactory. The contractor shall promptly remove all rejected material from the site. All materials shall be handled carefully, to prevent damage to protective coatings, linings, and joint fillings; preclude contamination of interior areas; and avoid jolting contact, dropping, or dumping.

All work and materials are subject to tests by the owner at such frequency as may be determined by the city engineer or designee.

While suspended and before being lowered into laying position, each pipe section and appurtenant unit shall be inspected by the contractor to detect damage or unsound conditions that may need corrective action or be cause for rejection. The contractor shall inform the city engineer or designee of any defects discovered and the city engineer or designee will prescribe the required corrective actions or order rejection.

Immediately before placement, the joint surfaces of each pipe section and fitting shall be inspected for the presence of foreign matter, coating blisters, rough edges or projections, and any imperfections so detected shall be corrected by cleaning, trimming, or repair as needed.

02205.3 INSTALLATION OF PIPE AND FITTINGS –Watermain Installation

All site grading must be completed, certified by the project engineer and all off-road grading equipment removed from the site before starting any public utility work.

Watermain and water services shall be placed with a minimum of 7.5 feet of ground cover from the top of pipe to finished grade. A minimum vertical separation of 18 inches must be provided between the outer surfaces of the pipes, with preference that the watermain cross above the sewer, wherever possible.

One full length of water pipe shall be located so both joints will be as far from the sewer as possible.

Watermain that is installed on a vertical slope with a 10% grade or steeper shall have all the joints along that slope tied.

Hydrants shall not be installed on the same side of the street as the sidewalk or trail.

If an existing property's service is to be interrupted notify the property owner 48 hours in advance. Interruption of existing service shall be confined to between the hours of 9 a.m. to 5p.m.

Water services shall be extended from the main to the back of the 10-foot easement where the curb stop will be placed. Minimum size of service is 1 inch O.D. A 1.5 inch O.D. or larger diameter service shall be installed where fire sprinklers are required or design dictates. See Standard Detail Plate [W-1](#).

Installation of Polyethylene Pipe (HDPE) and their appurtenances shall conform to the requirements of AWWA C906. The installation shall be to the bedding and backfill conditions specified by the manufacturer, plans, specifications, or special provisions.

AWWA C900 and C909 pipe should be installed in accordance with AWWA C605, Underground Installation of Polyvinyl Chloride (PVC) Pressure Pipe and Fittings for Water. The installation shall be to the bedding and backfill conditions specified by the plans, specifications, or special provisions.

Installation of ductile iron water mains (DIP) and their appurtenances shall conform to the requirements of AWWA C-600 Specifications, the plans, specifications, and special provisions.

In low-pressure areas, above elevation 1040 feet above sea level, the city will require pressure booster pumps within the structure at the service entrance. The city's building division codes shall apply for this requirement.

During any work involving the removal of a previously installed wet tap, replace with installation of a tee connection and a gate valve as determined by engineer.

02205.4 PIPE LAYING OPERATIONS –Watermain Installation

Trench excavation and bedding preparations shall proceed ahead of pipe placement to permit proper placement and joining of the pipe and fittings at the prescribed grade and alignment

without unnecessary hindrance. All foreign matter or dirt shall be removed from the inside of the pipe and fittings before they are lowered into position in the trench, and they shall be kept clean by approved means during and after the laying operation. The water main materials shall be carefully lowered into laying position by using suitable restraining devices. Under no circumstances shall the pipe be dropped or dumped into the trench.

Placement of public PVC or H.D.P.E pipe shall not occur after November 30th or before March 31st.

At the time of pipe placement, the bedding conditions shall be such as to provide uniform and continuous support for the pipe between bell holes. Bell holes shall be excavated as necessary to make the joint connections, but they shall be no larger than would be adequate to support the pipe throughout its length.

No pipe material shall be laid in water or when the trench or bedding conditions are otherwise unsuitable or improper. Maintain a minimum 18 inches of separation between the watermain and all other utility pipes.

When placement or handling precautions prove inadequate, in the city engineer or designee's opinion, the contractor shall provide and install suitable plugs or caps, effectively closing the open ends of each pipe section before it is lowered into laying position, and they shall remain so covered until removal is necessary for connection of an adjoining unit.

Tracer wire shall be placed along the side of the pipe and secured every 10 feet to the pipe with duct tape. Tracer wire shall be brought up alongside each hydrant barrel. The tracer wire to the hydrant shall be run inside a 3-foot-long section of 1-inch PE water service pipe from the terminus on the hydrant, down 2 feet into the soil. See Standard Detail Plate W2 for additional information.

As each length of bell and spigot pipe is placed in laying position, the spigot end shall be centered in the bell and the pipe forced home and brought to correct line and grade. The pipe shall be secured in place with approved backfill material, which shall be thoroughly compacted by tamping around the pipe to a height of at least 12 inches above its top. Mechanically compact all trenches in accordance with MnDOT [2106](#).

At all times when pipe laying is not in progress, including noon hour and overnight periods, all open ends of the pipeline shall be closed by watertight plugs or other means approved by the city engineer or designee. If water is present in the trench, the seals shall remain in place until the trench is pumped completely dry.

When connecting to existing stubs, the contractor shall take every precaution necessary to prevent dirt or debris from entering the existing lines. All necessary work to make the connection shall be done at no additional compensation, except where noted otherwise.

02205.5 GATE VALVES, BOXES, VALVE BOX BASES—Watermain Installation

All hydrants shall have a tracer wire run up along the barrel and terminated at a bracket on a top back flange bolt. Box bases shall be placed on Adaptors Inc. #6 valve box adaptor base or approved equal. Valve boxes shall be installed plumb and square to the valve, allowing a 4-inch PVC pipe to slide down the box and over the operating nut. All off road valve boxes, except for those on

hydrant leads, shall be marked with a flange post and a blue reflectorized metal marker plate with white G.V. lettering printed upon the plate. Marker plate shall be attached to the flange post using stainless steel bolts and nuts. The marker plate shall face the closest access road. The flange post shall be located 2 feet behind the box when facing the roadway.

02205.6 Jacking/Boring – Watermain Installation

The terms "auger", "boring", "jack", "jacking", and "tunneling" in the proposal, specifications, and plans refers only to non-open cut construction. The contractor shall inspect and verify soil conditions to their own satisfaction to determine the type of construction to employ. During construction, the contractor shall be responsible for protecting all existing utilities above or below the pipe invert.

The minimum inside diameter of the casing pipe shall be 4 inches greater than the outside diameter of the bell of the carrier pipe. For any installation beneath a railroad, the top of the casing pipe shall not be closer than the specified dimensions indicated in the railroad permit.

The steel casing minimum wall thickness shall be as specified on the plans, in the special provisions, or in the applicable permit. Where required by the city engineer or designee, two 17-pound anode packs shall be attached to the casing for corrosion protection.

A 1.5-inch pipe shall be forced along the top of the casing pipe. The front end of this pipe shall be 18 inches behind the front end of the casing pipe. A mixture of water and bentonite clay shall be forced through this pipe at all times during the casing installation to fill any voids that may be present above the casing pipe. Upon completion of the casing installation, this pipe shall be slowly withdrawn while bentonite is forced through the pipe to fill any remaining voids.

The contractor shall prevent excavated materials from flowing back into the excavation during the non-open cut construction. This shall include the use of a shield conforming to the size and shape of the casing that will prevent materials from flowing into the leading edge of the casing. The jacking machine used shall be capable of controlling line and grade and shall conform to the size and shape of the casing pipe.

No jacking/auguring of pipe will be allowed below the water table unless the water table has been lowered sufficiently to keep the water below the pipe being installed. The use of water under pressure (jetting) or puddling will not be permitted to facilitate jacking/auguring operations.

If any installation is augured, the head shall be approved by the city engineer or designee and the auger shall be located 6 inches behind the lead edge of the casing or carrier pipe.

If a void develops, the jacking/auguring shall be stopped immediately, and the void shall be filled by pressure grouting. The grout material shall consist of a sand/cement slurry of at least two sacks of cement per cubic yard and a minimum of water to assure satisfactory placement.

Skids and blocking shall be used as necessary to install the carrier pipe to the proper line and grade inside the casing pipe. Voids between carrier and casing pipes shall be filled with sand and the casing pipe sealed at both ends with a suitable material to prevent water or debris from entering the casing pipe.

02205.7 HORIZONTAL DIRECTIONAL BORING –Watermain Installation

Directional boring/drilling installation shall be accomplished where required on the plans or in the special provisions to minimize disturbance of existing surface improvements. The contractor shall be compensated for the restoration work only within the areas at the connection points, or other locations as may be approved by the city engineer or designee. The contractor shall be responsible for repairs, without compensation, for any other repair areas, including pit/boring points and areas above the drilled pipe where underground pressure may cause heaving or damage to pavement and ground surfaces.

The contractor must submit boring/drilling pit locations to the city engineer or designee for approval before beginning construction. Boring pits may be located within roadway right-of-way and easements as authorized by the city. Any other locations that may be desired by the contractor for boring pits or other uses shall be the responsibility of the contractor to attain authorization, including private property as may be required.

The drilling equipment shall be capable of placing the pipe as shown on the plans. The installation shall be by a steerable drilling tool capable of installing continuous runs of pipe without intermediate pits, at a minimum distance and radius requirements per the manufacturer's specification and recommendations. The guidance system shall be capable of installing pipe within 6 inches of the plan vertical dimensions and 12 inches of the plan horizontal dimensions. The contractor shall be required to remove and reinstall pipe, which vary in depth and alignment from these tolerances.

Copperhead Industries 7 by 7 Stranded Copper Clad Steel break load 4700 lbs. minimum or approved equal tracer wire shall be used. Two wires shall be pulled along with the HDPE or PVC pipe to locate it in the future. Conductivity between pipes shall be continuous.

Pull back forces shall not exceed the allowable pulling forces for the pipe being installed. The minimum radius of the pipe shall be per the manufacturer's specification and recommendations. Drilling fluid shall be a mixture of water and bentonite clay and shall be designed for existing soil conditions. Disposal of excess fluid and spoils shall be the responsibility of the contractor.

02205.8 POLYETHYLENE ENCASEMENT OF PIPELINE –Watermain Installation

For DIP watermain wherever so required by the plans, specifications, or special provisions, the pipeline, including valves, fittings, hydrant barrels, and appurtenances, shall be fully encased in polyethylene film meeting the requirements of these specifications. The film shall be furnished in tube form for installation on pipe and all pipe-shaped appurtenances such as bends, reducers, off-sets, etc. Sheet film shall be provided and used for encasing all odd-shaped appurtenances such as valves, tees, crosses, etc.

02205.9 REACTION BACKING –Watermain Installation

Reaction backing shall be provided at all watermain fittings and at the hydrant in accordance with the typical backing detail shown on the standard details. In any instance where the city engineer or designee determines that solid backing against undisturbed earth is not obtainable for fittings or hydrants, the contractor shall use stainless steel tie rods, ASTM F 593 Type 304 and or mechanical joint retainer glands as directed by the city engineer or a designee. **All vertical bends**

shall be secured with both mechanical joint retainer glands and two stainless steel tie rods. Mechanical joint retainer glands shall be tied to an adjacent fitting or back one full length of pipe. Bends larger than 45 degrees shall not be used without approval of the city engineer or designee.

02205.10 JOINING OF HDPE OR PVC PIPE –Watermain Installation

Sections of polyethylene or polyvinylchloride pipe shall be joined by the butt fusion process into continuous lengths at the job site. Extrusion welding or hot gas welding shall not be used. Butt fusion shall be performed only by a certified thermal fusion contractor. The contractor's certification shall be submitted to the city engineer or designee for review and approval prior to the start of construction. The joining method shall be the butt fusion method and shall be performed in strict accordance with the pipe manufacturer's recommendations. The butt fusion equipment used in the joining procedures should be capable of meeting all conditions recommended by the pipe manufacturer. The contractor shall be responsible to verify that the fusion equipment is in good operating condition and that the operator has been trained within the past twelve months. All welds will be made using a data logger to record temperature, fusion pressure, with a graphic representation of the fusion cycle shall be part of the quality control records.

Flanges/MJ adapters shall be attached to pipe fittings using butt fusion. The flanges/MJ adapters shall be aligned and centered relative to the pipe. Flanges/MJ adapters should be square with the valve or other flange before tightening of bolts. Bolts should not be used to draw flanges into alignment. Bolt threads shall be lubricated, and flat washers shall be used under flange nuts. Bolts shall be tightened using a star tightening pattern (see manufacturer's recommendations.) Twenty-four hours after first tightening the flange bolts, they must be re-tightened using the same star tightening pattern used above. The final tightening torque shall be as indicated by the manufacturer.

Polyethylene pipe and fittings may be joined using approved electro fusion couplings where the butt fusion method cannot be used. Fittings shall be PE4710 HDPE, Cell Classification of 345464C as determined by ASTM D3350-99. Electro fusion Fittings shall have a manufacturing standard of ASTM F1055. Fittings shall have a pressure rating equal to the pipe unless otherwise specified on the plans. All electro fusion fittings shall be suitable for use as pressure conduits, and per AWWA C906, have nominal burst values of three and one-half (3-1/2) times the Working Pressure Rating (WPR) of the fitting.

Mechanical joining may be used where the butt fusion or electro fusion methods cannot be used. Mechanical joining will be accomplished by either using a HDPE flange adapter with Ductile Iron back-up ring or HDPE Mechanical Joint adapter with a Ductile Iron back-up ring. Refer to the manufacturer's recommendations.

Pipe stiffeners shall be used where stiffening of the pipe is necessary for proper gasket seal. Pipe Stiffeners shall be ASTM-240-TP-304 Stainless Steel.

02205.11 REMOVE AND REPLACE WATERMAIN BOLTS

a. Replace watermain fitting and valve bolts and T-bolts with ASTM F 593 Type 304 stainless steel bolts while watermain is live. Replace only one bolt at a time. Apply anti-seize on stainless steel bolts.

- b. Replace top plate bolts with valve pinched wide open. Typically, there are four top plate bolts per valve.
- c. Replace the top nut (typically supplied by the city), and bolt inside of the top nut.
- d. Replace bonnet bolts with valve pinched wide open. There are approximately 12 bolts per valve.
- e. Remove bolts by using a vice grip or impact wrench.
- f. After replacing bolts, shut off valve completely to test for leaks. If leaks occur, open valve and tighten bolts.
- g. Apply automotive under coating to test plug when valve is dry. Wait 20 minutes for coating to dry before backfilling or replace test plug as directed by engineer.
- h. Furnish and install new valve box for each re-bolted valve.
- i. Aggregate bedding to be placed and compacted around valve as directed by engineer.
- j. Excavation and backfilling are included in the bid price.

02205.12 ADJUST GATE VALVE BOX

Includes adjusting casting to appropriate base course elevation and then to appropriate finished elevation. Adjustment to finished elevation shall be performed using risers for extensions of gate valves as outlined in Standard Detail Plate STRT-29. No payment will be made for additional adjustments.

02205.13 WATERMAIN STUBS PRESSURE RELIEVE PROVISION

All mainline watermain stubs shall have a provision to relieve residual pressure to allow for a safe connection in the future. The method may be either installation of a standard hydrant assembly at the end of the stub or an end cap on the stub with a corporation stop installed, 1-inch P.E. service pipe, curb stop with box and a length of P.E. service pipe, and 1-inch curb stop terminating above ground. See Standard Detail Plate [W-7](#). This will be considered incidental to the watermain installation.

02206 WATERMAIN TESTING

To assure quality materials and workmanship, the following tests shall be required unless waived by the city engineer or a designee. The city engineer or designee shall be present for all tests and shall be notified at least 48 hours in advance of the specific test by calling (763) 509-5500. Testing shall be completed after all the utility pipes have been installed in the area to be tested and prior to commencement of the street construction.

All tests shall be in accordance with CEAM standards or what is required within this specification. Individuals qualified to perform and evaluate such tests shall do all testing. The contractor shall pay for all tests required in these guidelines. Copies of the results shall be submitted to the city engineering division.

02206.1 PRESSURE TESTING OF WATERMAIN

Pressure test of the watermain shall be run at 150 psi for two hours with 0 (zero) pounds allowable pressure loss during the first hour and no more than two pounds allowable pressure loss during the second hour. Gauge to be used will be an [Ashcroft, Model 1279 or 1082](#), and 4.5 inches in diameter, in one psi increments or approved equal. Water lines shall be segmented using the installed valves to limit the maximum test segment length to approximately 1,200 feet.

02206.2 CONDUCTIVITY TESTING OF WATERMAIN

2024 STANDARD DETAIL SPECIFICATION FOR WATERMAIN CONSTRUCTION

[Back to Index page](#)

Conductivity testing of DIP watermain, copper straps or copper tipped gaskets shall be required to run at 350 amps for five minutes. PVC/HDPE watermain tracer lines shall be tested using a standard underground utility locator, demonstrating that the lines can be located. Welders may not be used on tracer wire locating/conductivity testing.

02206.3 DISINFECTION OF WATERMAIN

Disinfect pipelines prior to placing watermain in service in accordance with AWWA C651. The watermain initial fill shall be done by city personnel. The watermain initial fill shall sit in the pipe a minimum of 24 hours before flushing for the bacteria test.

02206.4 BACTERIA TESTING OF WATERMAIN

The watermain shall be flushed, in the presence of city personnel, of its concentrated chlorine from the initial filling.

Testing options A and B as described in AWWA C-651 and below shall be required for the bacteriological testing for total coliform analysis.

Option A: Before approving a main for release, take an initial set of samples after flushing and then resample again after a minimum of 16 hours using the sampling site procedures outlined. Both sets of samples must pass for the main to be approved for release.

Option B: Before approving a main for release, flush the main and let it sit for a minimum of 16 hours without any water use. Then collect, using the sampling site procedures outlined and without flushing the main, two sets of samples a minimum of 15 minutes apart while the sampling taps are left running. Both sets of samples must pass for the main to be approved for release.

The contractor shall have water samples taken in the presence of city personnel and analyzed by a certified laboratory. The laboratory's field technician shall collect the samples. A copy of the tests results must be sent to the city engineer for the project records. The report must contain the project name and the location where the sample was taken, the parts per million (PPM) of chlorine for each sample must fall between the EPA minimum of Mg/L of 0.20 ppm and a maximum of Mg/L of 4.0 ppm, as well as whether they pass or fail. City crews will perform a final flush of the mains and place them in service after successful testing of the system.

02207 MEASUREMENT AND PAYMENT


All items will be measured separately according to design designation as indicated in the pay item name and as may be detailed and defined in the plans, specifications, or special provisions. Pipe will generally be designated by size (inside diameter or span), strength class, kind or type, and laying condition.

Complete-in-place items shall include all component parts thereof as described or required to complete the unit, but excluding any excesses covered by separate pay items. Linear measurement of piping will include the running length of any special fittings (tees, bends, gates, etc.) installed within the line of measure between specified terminal points.

02208 WATERMAIN DETAILS PLATES - W-1 through W-8

NOTES:

1. HDPE SERVICE PIPE IS TO BE A CONTINUOUS PIECE. NO JOINTS, COUPLINGS, ETC., ALLOWED FROM THE MAIN TO THE CURB STOP.
2. HDPE WATER SERVICE TO HAVE A LOOP TO PROVIDE FOR SETTLEMENT.
3. CAP OR PIG TAIL HOUSE SIDE OF THE CURB STOP TO KEEP CLEAN
4. INSERT STIFFENERS REQUIRED ON ALL FLEXIBLE PLASTIC CONNECTIONS.
5. A STATIONARY ROD IS REQUIRED FOR ALL CURB STOPS.
6. SWING TIES ARE REQUIRED FOR WATER SERVICES.
7. ADJUST CURB STOP TOP TO 1" BELOW FINISHED GRADE.



CAPS
 McDONALD 5614LTW
 MUELLER 89375
 FORD TYPE PS-LID-TW

Z.5' EXTEND MINNEAPOLIS PATTERN CURB STOP BOXES W/RODS
 McDONALD 5614TW (1" SVC)
 McDONALD 5615TW (1½" SVC)
 MUELLER H-10300 / 88703 (1" SVC)
 MUELLER H-10300-99002/88703 (1½" SVC)
 FORD EM2-75-46-72R-TW (1" SVC)
 FORD EM2-75-47-72R-TW (1½" SVC)

CURB STOPS (BALL VALVE) MINNEAPOLIS PATTERN
 McDONALD 76104-22 OR 76104Q (1"-1½")
 MUELLER P-25155N OR B-25155N (1"-1½")
 FORD B44-444M-G-NL (1") OR
 FORD B44-444M-Q-NL (1")
 FORD B44-666M-G-NL (1½") OR
 FORD B44-666M-Q-NL (1½")

CORPORATION STOPS (BALL VALVE) WITH COMPRESSION FITTINGS
 McDONALD 74701B-22 (1"-1½" SVC) OR
 McDONALD 74701BQ (1"-1½" SVC)
 MUELLER P-25008N (1"-1½" SVC) OR
 MUELLER B-25008N (1"-1½" SVC)
 FORD FB1000-4-G-NL (1" SVC) OR
 FORD FB1000-4-Q-NL (1" SVC)
 FORD FB1000-6-G-NL (1½" SVC) OR
 FORD FB1000-6-Q-NL (1½" SVC)


STAINLESS STEEL SERVICE SADDLES
 SMITH-BLAIR 372
 FORD FS-313
 ROMAC 306 AND 305

CONTINUOUS, BLUE COATED, #12 SOLID COPPER OR COPPER CLAD STEEL, INSULATED TRACER WIRE FROM MAIN TO C.S. BOX CAP




STANDARD DETAILS
 SEWER AND WATER SERVICE CONNECTION
 CITY OF PLYMOUTH

PUBLISHED
 1-24
 CITY PL. NO.
 W-1
 REVISED 1-24








STANDARD DETAILS
 HYDRANT AND GATE VALVE INSTALLATION
 CITY OF PLYMOUTH

PUBLISHED
 1-24
 CITY PL. NO.
 W-2
 REVISED 1-24



STANDARD DETAILS
 TYPICAL MEGALUG LOCATION
 CITY OF PLYMOUTH

PUBLISHED
 1-24
 CITY PL. NO.
 W-3
 REVISED 3-23



VALVE BOX COVERS SHALL BE: TYLER 6865, SIGMA VB2600 OR APPROVED EQUAL

ADJUST V.B. TOP TO $\frac{1}{4}$ " TO $\frac{1}{2}$ " BELOW STREET GRADE OR $\frac{1}{2}$ " TO 1" BELOW FINISHED BLVD. GRADE AND SHALL BE SET SO AS TO PROVIDE 12" OF UPWARD ADJUSTMENT.

FINISHED GRADE

14" MIN. FROM TOP OF BOTTOM SECTION TO TOP OF VALVE BOX

GATE VALVE BOXES:

TYLER PIPE SERIES 6860 OR SIGMA VB630 SCREW TYPE WITH A #6 BASE AND DROP LIDS WITH "WATER" LABELED ON COVER OR APPROVED EQUAL

NO TRACER WIRE NEEDED FOR THE VALVE BOXES UNLESS OTHERWISE DIRECTED

VALVE BOXES SHALL BE INSTALLED PLUMB AND SQUARE TO THE VALVE, ALLOWING A 4" PVC PIPE TO SLIDE DOWN THE BOX AND OVER THE OPERATING NUT.


INSTALL ADAPTOR INC.'S VALVE BOX ADAPTOR #6 BASE OR APPROVED EQUAL

GATE VALVE BOXES ARE 3 PIECE, 5-1/4" SHAFT

GATE VALVES

AMERICAN FLOW CONTROL 2500 SERIES RESILIENT WEDGE TYPE GATE VALVES. VALVE BODY BOLTS SHALL BE ASTM F593 TYPE 304 STAINLESS STEEL.


NOTE: ALL BOLTS, T-BOLTS, NUTS AND RODDING INSTALLED BELOW GRADE SHALL BE ASTM F593 TYPE 304 STAINLESS STEEL.



STANDARD DETAILS
GATE VALVE AND BOX INSTALLATION
CITY OF PLYMOUTH

PUBLISHED
1-24
CITY PL. NO.
W-4
REVISED 3-23


NOTE: ALL BOLTS, T-BOLTS, NUTS AND RODDING INSTALLED BELOW GRADE SHALL BE ASTM F593 TYPE 304 STAINLESS STEEL. EACH BOLT SHALL BE CLEARLY STAMPED AS A 304 STAINLESS STEEL BOLT. (THIS INCLUDES ALL VALVE AND SLEEVE BODY HARDWARE)



STANDARD DETAILS
WATERMAIN WET TAP
CITY OF PLYMOUTH


PUBLISHED
1-24

CITY PL. NO.
W-5
REVISED 1-24



SAND SHALL CONFORM WITH
MN/DOT SPEC. 3149.2B

NOTE:
BEDDING SHALL BE CONSIDERED INCIDENTAL TO THE PIPE
UNLESS MODIFIED IN THE CONTRACT DOCUMENTS.




NOTE: WATERMAIN PIPE SHALL BE C900 UNLESS OTHERWISE NOTED.



STANDARD DETAILS
WATERMAIN BEDDING
CITY OF PLYMOUTH

PUBLISHED
1-24
CITY PL. NO.
W-6
REVISED 1-24

USE THIS BLOW OFF ASSEMBLY AT THE DEAD END OF A WATERMAIN IN LIEU OF A HYDRANT INSTALLATION.




PER WATERMAIN SPECIFICATION 02205.13 WATERMAIN STUBS PRESSURE RELIEVE PROVISION



STANDARD DETAILS
 WATER MAIN STUB BLOW OFF DETAIL
 CITY OF PLYMOUTH

PUBLISHED
 1-24
 CITY PL. NO.
 W-7
 REVISED 1-19



- NOTE:
1. SELECT GRANULAR REQUIRED FOR ALL BEDDING
 2. ALL VERTICAL BENDS SHALL BE TIED WITH SS RODDING. 2 RODS CONNECTING EACH JOINT 180° APART.
 3. TRACER WIRE TO BE RUN WITH OFFSET PVC PIPE. (IF EXISTING WM IS CIP OR DIP, PINCH EXPOSED COPPER TRACER WIRE BETWEEN DOUBLE NUT ON EXISTING SIDES)
 4. MEGALUGS MANUFACTURED BY EBAA IRON, SIGMA, SIP OR APPROVED EQUAL SHALL BE USED AT ALL MECHANICAL JOINTS
 5. ALL BOLTS, T-BOLTS, NUTS AND RODDING INSTALLED BELOW GRADE SHALL BE ASTM F593 TYPE 304 STAINLESS STEEL
 6. ADDITIONAL RODDING AND MEGALUGS MAY BE REQUIRED BY ENGINEER.



STANDARD DETAILS
 VERTICAL OFFSET DETAIL
 CITY OF PLYMOUTH

PUBLISHED
 1-24
 CITY PL. NO.
 W-8
 REVISED 1-24