

PLAN

RETAINING WALL

CULVERT

STEEL CASING

NOTES:

- CASING INSTALLATION ONLY IF APPROVED BY THE CITY ENGINEER.
- INSTALL STEEL CASING AROUND CULVERT UNDER THE PROPOSED RETAINING WALL LOCATION.
- CASING INSIDE DIAMETER SHALL BE A MINIMUM OF 1' LARGER THAN THE BELL OF THE CULVERT PIPE.
- THE CASING SHALL EXTEND A MINIMUM OF 2' OUT FROM THE FRONT AND BACK OF THE RETAINING WALL.
- CASING AND INSTALLATION SHALL BE INCIDENTAL TO THE WALL CONSTRUCTION.

RETAINING WALL

STEEL CASING

CULVERT

PROFILE



STANDARD DETAILS
RETAINING WALL CULVERT CASING DETAIL
CITY OF PLYMOUTH

PUBLISHED
1-24

CITY PL. NO.
ST-14
REVISED 3-15